



# ASHRAE's LowDown Showdown

---

Presented to the Building Energy Simulation Forum  
14 February 2018

James Cullin, PhD, PE

# Overview

---

Project Approach

Existing Building  
Modeling/Calibration

Proposed Design

Proposed Building  
Modeling

Renewables

Results/Outcomes


Lessons Learned



# ASHRAE "Lowdown Showdown"

## Conceptual retrofit of existing library archival facility

- Energy consumption comparable to coffee shop
- Required 24/7/365 setpoint control to 60°F and 40% RH
- Issues with project documents did not match building
- Limitation on renewables capacity



# Six-Step Design Approach

---



**Set Aggressive Goals**



**Choose Efficient Systems**



**Analyze the Climate**



**Opt for Renewables**



**Reduce Loads**



**Verify Performance**

# Lowdown Showdown - Approach

---

- Model existing building, calibrate to electric bill data
- Identify main sources of energy consumption
- Create energy reduction strategies
- Judging criteria: feasibility, cost effectiveness, energy performance



# Design Goals



---

- Understand main consumers of energy in existing building
- Focus efforts on making archival bays as efficient as possible
- Develop an innovative, interactive design
- Apply renewables to approach Net Zero Energy




# Modeling Baseline

- Drafted from design documents
- Large amount of airflow through AHUs
- Workaround required for modeling desiccant wheel



# Desiccant Wheel

- Not modeled directly with IES
- Modeled with additional cooling + heating coil
- Overestimates energy usage








# Calibration

- Limited variables we could change
- Infiltration unknown and often underestimated
- Fan static pressure
- Chiller efficiency

Energy Consumption Over Time



# Building Loads



# LowDown Showdown – Efficiency Measures



---

- Insulate vertical walls + green west wall
- Roof canopy shades from direct solar, provides platform for PV
- Operational awareness to reduce infiltration
- Lighting inspired by data centers (“follow-me” style)



# Envelope Gains


- Add insulation on vertical walls
- Fly roof shades building from overhead direct solar gain and provides PV platform
- Reduced infiltration via verifying building tightness
- Increased operational awareness to minimize doors opening




# Reduced Lighting

---

- Existing lighting power density = 1.5 W/sf
- Proposed lighting power density = 0.6 W/sf
- **"Follow Me" style occupancy controls**
  - Large floor plate
  - Only a small fraction of space needs lit at any given instant—where the workers are
- Resultant ~75% decrease in lighting energy





# Heat Recovery



# Isolating Ventilation

- Reducing loads means ventilation can be decoupled from other space conditioning
- Deliver code-required outside air (600 CFM per bay) at interior design conditions
- Low-RPM large-diameter ceiling fans for destratification
- Utilize efficient secondary system to handle envelope and internal loads









# Custom AHU for Storage Bays

---


- Hydronic preheat
- Desiccant dehumidification with hot gas regeneration
- DX coil
- Evaporative pad humidifier
- Powered exhaust with 80% effective total heat recovery wheel




# Modeling Proposed

## Challenges:


- Heat Recovery
- Desiccant Wheel
- Chilled Beams
- Ceiling Fans
- Geo Loop



# Modeling Proposed



# Holding Set Point



# Renewables


---

- Use 10,000sf of roof canopy for PV
- **Analysis with NREL's** PVWatts tool estimates 1,179 kWh/kW of installed PV
- Panel density of 18 W/sf -> 180kW array
- Provides EUI offset of 11 kBtu/sf/yr




# Energy Breakdown

Existing Conditions



Proposed Conditions




- Pumps & Aux
- Head Rejection
- Space Cooling
- Plug Loads
- Lights
- Ventilation Fans
- Domestic Hot Water
- Space Heating

- Pumps & Aux
- Head Rejection
- Space Cooling
- Plug Loads
- Lights
- Ventilation Fans
- Domestic Hot Water
- Space Heating
- Savings


# Lowdown Showdown - Outcomes

- 82% energy savings prior to inclusion of PV
- Savings in ventilation key – only deliver the air you need
- \$1.2M estimated cost, but payback in 5 years

**EUI Breakdown for the Baseline**



**EUI Breakdown for the Proposed Design**



**KEY**

- Plug Loads
- Interior Lights
- Space Heating
- Space Cooling
- Heat Rejection
- Pumps & Aux
- Ventilation Fans
- Domestic Hot Water
- PV

# Results Summary

LDSD RESULTS SUMMARY	BASELINE	SUSTAINABILITY SAVANTS	
Total Energy Usage (kBtu)	10,600,000	1,800,000	↓
Site EUI (kBtu/sf/year)	173	18.6	↓
Source EUI (kBtu/sf/year)	535	55.3	↓
Annual Electricity Usage (kWh)	3,105,000	528,000	↓
Annual Water Usage (gal)	12,500	12,500	→
Annual Electricity Cost	\$250,900	\$25,500	↓
Annual Water Cost	\$500	\$500	→
Total Annual Costs	\$251,400	\$26,000	↓
Cost Per Square Foot	\$4.10	\$0.42	↓
Total Energy Generation (kBtu)	0	724,000	↑
Net Energy (kBtu)	10,594,000	1,078,000	↓
Carbon Equivalent (tons CO <sub>2</sub> /year)	2,160	220	↓



# Lessons Learned

---

- Calibrating a model with limited design data requires **setting a “good enough”** criteria
- Still uncertainty when actual **site conditions can't be known** due to project constraints
- Workaround necessary for reasonable modeling of desiccant wheel
- Load reduction was key in creating a highly efficient design





# Creating a better environment

---

James Cullin, PhD, PE

Mechanical Engineer

[james.cullin@pae-engineers.com](mailto:james.cullin@pae-engineers.com)

503-226-2921

522 SW 5th Ave, Suite 1500  
Portland, OR 97204