

Active Antifreeze

Page 1 of 2 Use Avery labels #5163

COLD WATER SHUTOFF

- To service hot water system.
- **OPEN** for normal operation.
- **CLOSE** if hot water system needs service.

© Bonneville Power Administration

ISOLATION VALVE

- Allows bypass of solar system from backup water heater.
- **OPEN** for normal operation.
- **CLOSE** for bypass of solar.

© Bonneville Power Administration

ISOLATION VALVE

- Allows bypass of solar system from backup water heater.
- **CLOSE** for normal operation.
- **OPEN** for bypass of solar.

© Bonneville Power Administration

EXCHANGER FILL VALVE

- Used to fill the collector loop with fluid.
- Normally closed. Should only be opened by qualified service person to flush/fill collector fluid.
- **DANGER—FLUID NOT DRINKABLE!**
- Fill only with a propylene glycol and water mixture.

© Bonneville Power Administration

PRESSURE REGULATOR

- Limits incoming water pressure to the system
- Set at 70 psi or less.
- **DO NOT** adjust above 70 psi.

© Bonneville Power Administration

TEMPERING VALVE

- Blends very hot water with cold to prevent scalding.
- Adjustable. Set to same temperature as water heater thermostats.

© Bonneville Power Administration

ISOLATION VALVE

- Allows bypass of solar system from backup water heater.
- **OPEN** for normal operation.
- **CLOSE** for bypass of solar.

© Bonneville Power Administration

EXCHANGER DRAIN VALVE

- Used to drain/flush collector loop fluid.
- Normally closed. Should only be opened by qualified service person to drain/flush collector fluid.
- **DANGER—FLUID NOT DRINKABLE!**

© Bonneville Power Administration

FLOW METER

- Indicates rate of fluid flow through collector loop in gallons/minute.
- Read top of float when pump is on. Correct flow rate for this system is _____ gpm.

© Bonneville Power Administration

Active Antifreeze

Page 2 of 2

COLLECTOR LOOP PRESSURE RELIEF VALVE

- Prevents buildup of excess pressure in the solar collector loop.
- Automatic, non-adjustable, set at 75 psi. If fluid runs continually from this valve, call dealer for replacement.

© Bonneville Power Administration

TANK DRAIN

- Used to drain and/or flush the solar storage tank.
- Refer to Monitoring and Maintenance Instructions posted on or near this solar storage tank for required procedure.

© Bonneville Power Administration

BALL VALVE

- Used to adjust flow in collector loop.
- Operate only if needed to adjust flow. (Refer to flow meter.)

© Bonneville Power Administration

PUMP ISOLATION VALVE

- Allows isolation of the pump from the circulation loop plumbing.
- **OPEN** for normal operation.
- **CLOSE** for isolation

© Bonneville Power Administration

SOLAR SYSTEM CONTROLLER POWER

- **DO NOT UNPLUG** (except to service).

© Bonneville Power Administration

TEMPERATURE GAUGE

- Measures temperature of water after pre-heating by the solar system.
- Gauge is accurate when using hot water anywhere in the house.

© Bonneville Power Administration

PRESSURE GAUGE

- Measures pressure in the collector fluid loop.
- Can be read anytime. Should read between 7-30 psi. If outside this range, call dealer for service.

© Bonneville Power Administration

ISOLATION VALVE

- Allows bypass of solar system from backup water heater.
- Turn handle clockwise to bypass solar (1/4 turn).
- Turn handle counterclockwise for normal operation (1/4 turn).

© Bonneville Power Administration

PUMP ISOLATION VALVE

- Allows isolation of the pump from the circulation loop plumbing.
- **OPEN** for normal operation.
- **CLOSE** for isolation

© Bonneville Power Administration